



| | | | |
|------------------------------------|---------------------------------------|--------------------|--------|
| 1 | Cover according to standard EN124 (☒) | Class | Weight |
| | | A35 (3,5 t) ☐ | 13 kg |
| | | B125 (12,5 t) ☐ | 45 kg |
| | | C250 (25 t) ☐ | 55 kg |
| 2 | Maintenance shaft (☒) | D400 (40 t) ☐ | 90 kg |
| | | 800...1000 ☐ | 31 kg |
| | | 1000...1250 ☐ | 33 kg |
| | | 1250...1500 ☐ | 42 kg |
| | | 1500...1750 ☐ | 52 kg |
| | | 1750...2000 ☐ | 62 kg |
| 3 | Ladder | 2000...2250 ☐ | 71 kg |
| | | 2250...2500 ☐ | 80 kg |
| | | Automatic closure | |
| | | Coalescing modules | |
| | | Sludge trap | |
| Oil storage capacity | | 3400 l | |
| Effective capacity | | 19200 l | |
| Oil level alarm sensor (☒) | | ☐ | |
| Nominal flow rate | | 80 l/s | |
| Total capacity | | 35200 l | |
| Weight excluding manhole shaft/lid | | 3100 kg | |

| | | | | | | | |
|---|-------------|------------|----------------|-------------------|---------------|--------------|--|
| Product | NS | Name | SEPKO 80/16000 | | Scale | 1:1 | |
| Design by | M.Skuinskas | Checked by | E.Mozuraitis | Approved by | E.Kuodis | Drawing type | |
|  UAB ENKA Vandziogalos g. 94 LT-47467 Kaunas, Lithuania tel. +37037377441, faks. +37037377907 www.enka.lt, info@enka.lt | | | | Construction site | Drawing no. | | |
| | | | | | NS200-13-80BS | | |
| | | | | Date | Lang. | Sheet | |
| | | | | 10/28/2016 | en | 1 | |